



To: All Potential Offerors  
From: Gary Prosocki, Procurement Specialist  
Date: June 29, 2022  
Subject: RFP 467-22, Temperature Monitoring Addendum #2

Please add this Addendum #2 to the original RFP documents. It shall be the responsibility of the interested Offerors to adhere to any changes or revision to the RFP as identified in this Addendum #2.

**The following questions, and our responses, received as of 6/29/2022, shall be made a part of the procurement file:**

Question: Pursuant to Section III 1a. Is 5GHZ a requirement or is 2.4GHZ acceptable?

Response: Previously addressed - 2.4 is acceptable but MUST use WPA2 Enterprise and we only support 802.11G and N.

Question: Pursuant to Section III 1a. If 5GHZ is an absolute requirement (see above) Can a Non-Direct wifi solution (ex. temperature sensors send data via RF to centralized data translation gateways, which connect via Wifi) be acceptable? (this is not required if 2.4GHZ is acceptable)

Response: See above.

Question: Pursuant to Section III 1a. What specific 802.1x features are required? (Ex. PEAP w/ MSCHAPv2)

Response: All features of 802.11 G and/or N.

Question: Pursuant to Section III paragraph 1, If the answer to Question one is that your requirements are 5GHZ, and the answer to Question 2 is acceptable, Please list the different facilities, the number of floors per facility, and the number of sensors per location so we can estimate the required number of WiFi gateways needed for the installation. (typically one Wifi gateway per floor)

Response: I have consulted our Network engineer and they do not understand the question about the required number of WiFi gateways. This is not needed as DHCP will provide the gateway.